

**Bylaw 16200
Drainage Bylaw
Code of Practice**

**Oil, Grease & Sand Interceptor
Installation & Maintenance Requirements**

Vehicle/Equipment Service & Washing

APPROVED:

Chris Ward, Branch Manager, Drainage Services
Delegate of the City Manager

January __6__, 2014

1.0 Application

1.1 The owners of all premises in which vehicles or equipment are:

- (i) serviced;
- (ii) repaired;
- (iii) disassembled; or
- (iv) washed

must install an oil, grease and sand interceptor.

s. 15(2)

1.2 The owner of a premises must install an interceptor when required to do so by the City Manager.

s. 15(3)

1.3 All required interceptors must be installed and maintained in accordance with the code of practice established by the City Manager.

s. 15(4)

1.4 Nothing in this code of practice exempts a person from complying with all applicable municipal, provincial, or federal legislation or standards.

2.0 Installation Requirements

2.1 All oil, grease, and sand interceptors required to be installed by section 15(2) or 15(3) of the Drainage Bylaw must be of sufficient capacity and appropriate design based on the nature of the premises.

2.2 All interceptors must be installed either:

- a) on all fixtures that may release oil, grease, or sand; or
- b) downstream of all fixtures that may release oil, grease, or sand.

s. 15(2)

3.0 Maintenance Requirements

3.1 All oil, grease, and sand interceptors must be maintained in a fully operational and effective condition.

3.2 All oil, grease, and sand interceptors must be inspected at least annually.

3.3 All oil, grease, and sand interceptors must be cleaned:

- a) when the depth of oil, grease, or sand exceeds 50% of the liquid volume capacity of the interceptor;
- b) when the discharge from the facility exceeds the limits set out in Bylaw 16200; or
- c) as required by the City Manager.

4.0 Installation & Maintenance Records

4.1 The following inspection and maintenance records must be retained for a period of two years, and must be made available for review by the City Manager upon request:

- a) date of inspection and/or maintenance of the interceptor;
- b) percentage of sand in the interceptor at the time of inspection;
- c) nature of maintenance activities performed;
- d) quantity of material removed from the interceptor when maintained;
- e) disposal location of material removed from the interceptor; and
- f) name of the person performing the inspection or maintenance.

4.2 The information required by section 4.1 must be recorded on the attached Maintenance Log – Oil, Grease & Sand Interceptor. Completed Maintenance Logs must be retained for a period of two years, and must be made available for review by the City Manager upon request.

Maintenance Log – Oil, Grease & Sand Interceptor

Facility Name: _____ Address: _____ Maintenance Company: _____

Date (dd/mm/yy)	Inspection Conducted (Yes/No)	Maintenance Conducted (Yes/No)	% Sand	Maintenance Performed	Quantity Removed	Disposal Location	Conducted By

The personal information collected on this form is collected under the authority of section 33(c) of the *Freedom of Information and Protection of Privacy Act* (Alberta) for the purpose of managing the maintenance of oil and grease receptors as required by City of Edmonton Bylaw 16200, the Drainage Bylaw. If you have any questions regarding this collection please contact the Director, Public & Regulatory Services at 780-496-5570.