

Customer Connection Guide Updates

For all Electrical rooms located below grade a ¾" conduit (continuous with no fittings) must be run between the meter room and a 6" X 6" PVC box mounted to the closest exterior wall of the building. A 120 volt electrical outlet must be supplied next to this conduit in the meter room. (to be added to sections - 8.1, 8.2, 8.5, 8.6, and 8.7)

All Electrical rooms must have 4 walls and a ceiling.

CT cabinets must be a minimum of 6" off the floor to a maximum of 7' to the top of the cabinet.

For further questions please contact

Gerry Wiles

gerry.wiles@edmonton.ca

780-423-5862



Client Relations, Development Services Branch

Sustainable Development, City of Edmonton

currentplanningrelations@edmonton.ca

If you no longer wish to receive news via email from the Development Services Branch, please contact currentplanningrelations@edmonton.ca or 780-944-0743.