

Commercial Building - Final Inspection

This inspection, when passed will produce the final occupancy document. Request this inspection when:

- Pre-final documents have been submitted in selfserve.edmonton.ca and the review is completed. Review the [Commercial Building Inspections](#) page for more information.
- Work is complete and work site does not resemble a construction site
- Site is safe to access by the general public:
 - Combustible materials (wood, paint, gas, propane) removed from site
 - Construction materials and equipment removed from site
 - Hard surface is available to access front door
 - Handrails and fall guards installed (temporary measures permitted)
- Fire suppression systems are operational:
 - Life safety devices are operational
 - Protective caps removed from detectors
 - Tape/clips removed from sprinkler heads
 - Fire rating door labels are visible
 - Door closers installed on fire-rated doors
 - Exit signage is in place
 - Fire extinguishers are installed
 - Emergency lighting is operational
- Paper copies of permits and City-reviewed plans available on site
- Authorized alternative solution form available on site (if applicable)