

## HVAC - Stack Inspection

This inspection is necessary to view all HVAC work above the basement level.

Request this inspection when all HVAC exhaust, intake, supply and return air ducts are installed and prior to drywall enclosure of the floors above the basement or lowest level (pre-concealment)

### Prepare

Learn about [how to prepare for your inspection](#).

### Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- Roof flashings for exhaust termination clearance
- Hood locations/clearances
- Required documentation on site regarding equipment zoning, capacities, efficiencies and primary ventilation fan location
- Ductwork system review (sealing, sizing and location)
- Required ventilation equipment (KE/bath fans/HRV duct system)
- Heat losses completed using F-280
- Mechanical ventilation system manufacturers' information on site