

When to use this checklist

This inspection is necessary for commercial hydronic installations when the hydronic piping is installed and still exposed for inspection.

Prepare

Learn about [how to prepare for your inspection](#).

Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- Hydronic loops and maximum lengths are installed and comply with CSA B214.
- Manifolds and tubing air test assembly is installed and holding pressure (accessible without a ladder or lift)