

When to use this checklist

This inspection is necessary when the plumbing work has been completed. After groundworks and stacks are completed satisfactorily.

Prepare

Learn about how to prepare for your [Residential](#) or [Commercial](#) inspection.

Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- All fixtures and faucets are installed and operational
- Previously identified deficiencies are corrected
- Supply and drain connections are complete
- Grease interceptors, indirect connections, and water service/supply backflow devices may be required.