

When to use this checklist

This inspection is necessary when new or renovated piping for drainage and water supply is installed above grade.

Prepare

Learn about how to prepare for your [Residential](#) or [Commercial](#) inspection.

Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- All piping is exposed for visual inspection; no drywall, insulation, vapour barrier or spray foam has been installed
- In-wall and above-ceiling piping has been installed and meets the National Plumbing Code (NPC) standards:
- Pipes have proper grade and adequate support
- Water supply lines are properly sized
- Rough-in valves are to be installed and CSA approved
- Waterlines and drainage piping to be protected from freezing
- Appropriate piping materials to be installed for that application