

## **When to use this checklist**

This inspection is necessary when Temporary Heating supply and appliances have been installed, before being put into operation.

## **Prepare**

Learn about how to prepare for your [Residential](#) or [Commercial](#) inspection.

## **Check**

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- Piping has been installed and meets the CSA B149.1 Natural Gas and Propane Installation Code and the CSA B149.2 Propane Storage and Handling Code
- Regulators have the proper clearances to windows and are not located inside the building
- Heaters have the proper clearances to combustibles
- Proper clearances and protection for cylinders, tanks and heaters
- Ensure tanks and equipment are protected from construction equipment and traffic
- Temporary furnaces must meet manufacturer's specific requirements to be used for construction heat or warranties will be voided.