



|  |     |        |
|--|-----|--------|
| 7. Are there openings or gaps in the fence that would allow small pets to escape?  | YES | Notes: |
|  | NO  |        |
| 8. Has the right fencing material been used according to the detail?   | YES | Notes: |
|  | NO  |        |
| <i>Note: For example, wood screen instead of chain link fence and 100mm posts instead of 150mm posts. The consultant may submit a red line requesting approval of the change. Fencing material shall be consistent with the approved detail drawing.</i> |     |        |
| 9. Are the fence posts in alignment?   | YES | Notes: |
|  | NO  |        |
| <i>Note: Posts may need to be straightened or aligned, if necessary. The fence shall be installed completely within the appropriate property line.</i>   |     |        |
| 10. Is the fence leaning?  | YES | Notes: |
|  | NO  |        |
| <i>Note: A leaning fence may be due to a number of factors including, but not limited to, adjacent construction damage, machinery hitting the fence, from excavation, improper construction of footings, etc.</i>  |     |        |
| 11. Has the fence been installed of the correct height requirement?  | YES | Notes: |
|  | NO  |        |
| <i>Note: Height of fence must meet the detailed height on the approved drawing. A red-line is required for any changes that exceed the minimum fence height.</i>   |     |        |
| 12. Does the fence end with a terminal post?   | YES | Notes: |
|  | NO  |        |
| <i>Note: If the parcel extends more than 60cm past the end post a terminal post will be required. All chain link, tubular steel and wrought iron fences must have terminal posts.</i>  |     |        |
| 13. Are appropriate fasteners used?  | YES | Notes: |
|  | NO  |        |

.....

**B) WOOD SCREEN FENCE**

|   |     |        |
|---|-----|--------|
| 1. Is there evidence of extreme twisted posts?  | YES | Notes: |
|   | NO  |        |
|   | N/A |        |
| <i>Note: If the post is twisted to where it shows signs of impacting the fascia and the strength of fence panel (noted by how it is secured, push tests, etc.), the post should be replaced. As a rule of thumb, extreme twisted posts have a greater than 30 degree twist. Posts that are not extremely twisted are acceptable, but are subject to the inspector's discretion.</i> |     |        |
| 2. Are there protruding nails, screws, and/or staples?  | YES | Notes: |
|   | NO  |        |
|   | N/A |        |

|   |     |        |
|---|-----|--------|
| 3. Are cut ends of wood missing stain or paint?                 | YES | Notes: |
|   | NO  |        |
|   | N/A |        |
| 4. Is the step-down installed as shown on the approved drawing? | YES | Notes: |
|   | NO  |        |
|   | N/A |        |

.....

**C) CHAIN LINK FENCE**

|  |     |        |
|--|-----|--------|
| 1. Are there missing caps?   | YES | Notes: |
|  | NO  |        |
|  | N/A |        |
| 2. Are there bent, dented or damaged posts and rails?  | YES | Notes: |
| <i>Note: If there is evidence that the owner or builder have bent, dented or damaged posts, then those posts, will not constitute rejection of the CCC.</i>  | NO  |        |
|  | N/A |        |
| 3. Is there damaged mesh?  | YES | Notes: |
| <i>Note: If there is evidence that the owner or builder have damaged the mesh, then that mesh, will not constitute rejection of the CCC.</i>   | NO  |        |
|  | N/A |        |
| 4. Are there missing or damaged components such as the tension wire, tension bar, tension band, HOG rings, or ties?  | YES | Notes: |
|  | NO  |        |
|  | N/A |        |
| 5. Is there too much movement on the top rail between end post, line post, and terminal post?  | YES | Notes: |
|  | NO  |        |
|  | N/A |        |
| 6. Is mesh and tension wire/band too loose?  | YES | Notes: |
|  | NO  |        |
|  | N/A |        |
| 7. Are the gates on the plan installed without fully being able to open, close, and or latch?  | YES | Notes: |
|  | NO  |        |
| <i>Note: Gates shall have all moving parts working and gates are not blocking any existing landscaping on City property. Ensure gates are shown on approved plan. This must also include latch detail information.</i> | N/A |        |

